

# Agrichem Analytical Drinking Water Report

409 Stewart Rd  
Salt Spring Island, BC  
V8K 1Y6

Phone: 250.538.1712  
web: www.agrichem.ca  
email: info@agrichem.ca

Salt Spring Bottled Water  
239 Armand Way  

---

*current treatment*  
treated

*sample* 90610  
*date received* 10-Mar-15  
*time/temperature* 12:00 10 °C  
*date of report* 20-Mar-15  
*sampled by* agrichem

*Potable Water Quality Standards*

	<i>Health Canada (2008)</i>	<i>Island Trust (2001)</i>
<i>Total Coliforms</i>	0 MPN/100ml	0
<i>E. coli</i>	0 MPN/100ml	0
<i>pH</i>	6.59	6.5 to 8.5 *
<i>Conductivity</i>	241 uS/cm	no limit set
<i>Total Dissolved Solids (TDS)</i>	150 mg/L	500*
<i>Hardness (as CaCO3)</i>	100 mg/L	80-100
<i>Alkalinity (as CaCO3)</i>	79 mg/L	no limit set
<i>Residual Chlorine</i>	< 0.02 mg/L	0
<i>Turbidity</i>	< 0.05 NTU	****
<i>Fluoride (F)</i>	0.08 mg/L	1.5 **
<i>Chloride</i>	6.42 mg/L	250 *
<i>Nitrate (N)</i>	0.26 mg/L	10 **
<i>Nitrite (N)</i>	< 0.01 mg/L	3.2 **
<i>Phosphate (P)</i>	< 0.02 mg/L	no limit set
<i>Sulphate (S)</i>	1.98 mg/L	500 *
<i>Sodium (Na)</i>	6 mg/L	200 ***
<i>Potassium (K)</i>	0.7 mg/L	no limit set
<i>Magnesium (Mg)</i>	3.8 mg/L	500 *
<i>Calcium (Ca)</i>	33.8 mg/L	no limit set
<i>Iron (Fe)</i>	< 0.03 mg/L	0.3 *
<i>Copper (Cu)</i>	< 0.01 mg/L	1 *
<i>Manganese (Mn)</i>	< 0.01 mg/L	0.05 *
<i>Zinc (Zn)</i>	< 0.01 mg/L	5 *
<i>Arsenic (As)</i>	< 1 ug/l	10**
<i>Lead (Pb)</i>	< 2 ug/L	10**

< is "less than "      > is "greater than "

\* aesthetic - no health risk

\*\* maximum

\*\*\* 20 mg/L for restricted diets

\*\*\*\* surface water or surface influenced groundwater (drilled well) source 1 NTU \*\*

secure groundwater (drilled well) source 5 NTU \*

the presence of Total Coliform bacteria indicates surface influenced water source

For the Total Coliforms and E. coli method, 0 is UNDETECTED and is technically < 1 MPN/100ml

**This water sample meets the Health Canada Guidelines for Potability for all parameters tested.**